

Communities served by Southwest water treatment plant.

Required information on Great Lakes Water Authority's (GLWA) Administrative Compliance Agreement (ACA) with Michigan Department of Environment, Great Lakes, and Energy Drinking Water and Environment Health Division (EGLE):

Great Lakes Water Authority (GLWA) is required to notify water users of any unresolved significant deficiencies identified by the Michigan Department of Environment, Great Lakes, and Energy, Drinking Water and Environment Health Division (EGLE). Below is the status of significant deficiencies in the GLWA water system identified by EGLE:

Date Identified by EGLE	Description	Compliance Agreement Deadline	Status
08-02-2022	Improper rapid mixing and coagulant feed location at the Southwest water plant	12-31-2027	Contractor has been identified
08-02-2022	Inoperable flocculation equipment at the Southwest water plant	07-31-2031	Preliminary procurement phase